

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:30 pm

**PWS ID:** UTAH20053      **Name:** TURKEY PLANT (MORONI)  
**Legal Contact:** TURKEY PLANT (MORONI)      **Rating:** Approved  
NATHAN J MINER      **Rating Date:** 04/09/1996  
**Address:** PO BOX 308      **Activity Status:** Active  
MORONI, UT 84646  
**Phone Number:** 435-436-8211  
**City Served (Area):**  
**County:** SANPETE COUNTY  
**System Type:** Non Transient      **Last Inv Update:** 06/16/2009      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 05/27/2010      **Total Dsgn Cap:**  
**Population:** 380      **Surveyor:** JOHN L CHARTIER      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	MINER, NATHAN J		435-436-8211	435-427-9344	nminer@moronifeed.com

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Commercial	Unmetered	0	1
			1 Total Svc Connections

### Storage

**Total Storage:** 90,000 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	90,000 GAL			A	NO

### Distribution System

Pump Type	Total Dyn Head ft H2O    P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	10	250 GPM	250 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2	Active	WL	16	750 GPM	350 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	WELL #3	Active	WL	14	750 GPM	1,200 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.